



Details Index

Standard Detail Numbers And Description

<u>Detail No.</u>	<u>Standard Detail</u>	<u>General Details</u>
STD-001	Water Main Trench Detail Dated 6-21-2012	
STD-002	Alternate Pressure Testing Detail Dated 10-1-97	
STD-003	Typical Flushing Assembly Dated 8-19-2010	
STD-004	Plugging Abandoned Water Main Ends Dated 10-1-97	
STD-005	Cut-In-Valve Detail Dated 10-1-97	
STD-006	Typical Thrust Block Detail for Horizontal Deflection for Pipe Up To 16" Diameter Dated 1-15-98	
STD-007	Sleeve Installation Detail Dated 10-1-97	
STD-008	Spool Piece Installation Detail Dated 10-1-97	
STD-009	Typical Frostproofing Detail Dated 10-1-97	
STD-010	Typical Pavement Section Dated 2-6-98	
STD-011A	Construction Notes Page 1 Dated 5-22-2012	
STD-011B	Construction Notes Page 2 Dated 6-21-2012	
STD-012	Straight Cul-De-Sac Schematic Dated 6-14-2001	
STD-013	Standard Cul-De-Sac Hydrant/Loop Schematic Dated 6-14-2001	
STD-014	Alternate Cul-De-Sac Hydrant/Loop Schematic Dated 6-14-2001	
STD-016	Casing Detail No. 2 End of Casing and Casing Chock Detail Dated 1-21-2010	
STD-017	Clearance for Utilities - Plan View Dated 12-4-97	
STD-018	Clearance for Utilities - Profile View Dated 12-4-97	
STD-019	Crossing Large Ditches or Small Streams Profile- Open Cut Method - Dated 9-16-98	
STD-020	Crossing Large Ditches or Small Streams Section A-A Open Cut Method - Dated 9-16-98	
STD-021	Split Casing Detail - Dated 9-16-1999	
STD-022	Guardrail Details at Hydrant - Dated 10-15-1999	
STD-023	Service Connection Backfill Detail - Dated 10-7-2008	

Hydrant Details

<u>Detail No.</u>	<u>Standard Detail</u>
STD-H01	Disturbing Existing Leaded Hydrants and Leaded Fittings Dated 5-4-2006
STD-H02	Extend, Shorten and Adjust Hydrant Grade, Straight Type Dated 8-20-2012
STD-H03	Extend, Shorten and Adjust Hydrant to Grade, Offset Type 1 Dated 8-20-2012
STD-H04	Extend, Shorten and Adjust Hydrant to Grade, Offset Type 2 Dated 8-20-2012
STD-H05	Extend, Shorten and Adjust Hydrant to Grade, Offset Type 3 Dated 8-20-2012
STD-H06	Replacing Existing Hydrant with New 6" Hydrant, Straight Type Dated 5-4-2006
STD-H07	Replacing Existing Hydrant with New 6" Hydrant, Offset Type Dated 5-4-2006
STD-H08	Cut-In Tee for New Hydrant Installation on Existing Water Main Dated 10-1-97
STD-H09	Typical New Hydrant Installation Detail A Dated 3-4-2002
STD-H10	Typical New Hydrant Installation Detail B Dated 10-1-97
STD-H11	Typical New Hydrant Installation Detail C Dated 3-4-2002
STD-H12	Adjusting 6" Hydrant Elevation Dated 2-23-2005
STD-H13	6" Hydrant Elevation Dated 2-23-2005
STD-H14	Temporary Water Main & Hydrant Connection Assembly-A Dated 10-1-97
STD-H16	Temporary Water Main & Hydrant Connection Assembly-C Outlet End Dated 10-1-97
STD-H17	Temporary Water Service from Public Fire Hydrant Dated 3-16-2010
STD-H18	Temporary Water Service for Hose Connection from Public Fire Hydrant Dated 5-7-2013

Lowering Details

- STD-L01 Pipe Lowering Dated 11-24-2003
- STD-L02 Detail for Typical Water Main Lowering on Obstructions Less Than 24" in Diameter or Width for Existing Construction Dated 3-4-2002
- STD-L03 Detail for Typical Water Main Lowering on Obstructions 24"& Larger in Diameter or Width for Existing Construction Dated 3-4-2002
- STD-L04 Detail for Typical Water Main Lowering on Obstructions Less Than 24" in Diameter or Width for New Construction Dated 10-1-97
- STD-L05 Detail for Typical Water Main Lowering On Obstructions 24"& Larger in Diameter or Width for New Construction Dated 10-1-97
- STD-L06 Detail for Water Main Lowering Using Mechanical Joint Offsets under Obstructions Less Than 24" in Diameter or Width for New Construction Dated 12-3-2009
- STD-L07 Detail For Water Main Lowering Using Mechanical Joint Offsets under Obstructions 24" & Larger in Diameter or Width for New Construction Dated 12-3-2009
- STD-L08 Detail For Water Main Lowering Using Mechanical Joint Offsets Under Obstructions Less Than 24" in Diameter or Width for Existing Construction Dated 12-3-2009
- STD-L09 Detail For Water Main Lowering Using Mechanical Joint Offsets under Obstructions 24" & Larger in Diameter or Width for Existing Construction Dated 12-3-2009

Tee Details

- | <u>Detail No.</u> | <u>Standard Detail</u> |
|-------------------|------------------------------------|
| STD-T01 | Cut-In Tee Method #1 Dated 10-1-97 |
| STD-T02 | Cut-In Tee Method #2 Dated 10-1-97 |
| STD-T03 | Cut-In Tee Method #3 Dated 10-1-97 |

Air Relief Details

- | <u>Detail No.</u> | <u>Standard Detail</u> |
|-------------------|--|
| STD-A01 | 2" Air Relief Valve for Steel Water Mains Dated 5-15-2007 |
| STD-A02 | 2" Air Relief Valve for Concrete Mains Dated 5-15-2007 |
| STD-A03 | 2" Air Relief Valve for Ductile Iron Mains Dated 5-15-2007 |
| STD-A04 | 2" Air Relief/Flushing Outlet Valve for Steel Mains on Bridges Dated 8-11-2010 |

8" Regulator

8" Regulator Dated 10-1-97 and Bill of Material Dated 6-11-98

8" Regulator -Plan- Dated 10-1-97

8" Regulator - Elevation- Dated 10-1-97

8" Regulator Section A-A Dated 10-1-97

12" Regulator

12" Regulator Dated 10-1-97

12" Regulator -Plan- Dated 10-1-97

12" Regulator - Elevation- Dated 10-1-97

12" Regulator Section A-A Dated 10-1-97

Bill of Material Dated 8-04-2008

8" Check Valve In Vault

STD-8cv 8" Check Valve in Vault Dated 6-26-98

Connection Details

<u>Detail No.</u>	<u>Standard Detail</u>
STD-C01	Water Service Connection Extension or Replacement For 1" & Smaller Dated 5-11-98
STD-C02	Water Service Connection Extension for 1-1/2" & 2" Dated 10-1-97
STD-C03	Water Service Connection Replacement for 1-1/2" & 2" Dated 10-1-97
STD-C04	New 1" Service Connection Detail in Public Right Of Way Dated 8-1-2011
STD-C05	Two-Plex Setting for Remote Register Meter at Building -Plan- Dated 10-1-97
STD-C06	Two-Plex Setting for Remote Register Meter at Building -Profile- Dated 10-1-97
STD-C07	Three-Plex Setting for Remote Register Meter at Building Dated 10-1-97
STD-C08	Four-Plex Setting for Remote Register Meter at Building Dated 10-1-97
STD-C09	Extend 3" & Larger Connection - Dated 9-16-98
STD-C10	New Water Service Connection for 1-1/2" & 2" Dated 6-20-2000
STD-C11	3" and Larger Connection Dated 9-23-2008
STD-C14	Residential Service Connection Installation Detail with Meter in Vault Dated 9-28-2011
STD-C15	Residential Service Connection Detail with Meter in House Dated 9-28-2011

Meter Settings

<u>Detail No.</u>	<u>Standard Detail</u>
STD-M01	Standard 1-1/2" Meter Setting with 1-1/2" Meter for Vaults Dated 10-1-97 and Bill of Material 12-10-98
STD-M02	Standard 2" Meter Setting with 2" Meter for Vaults Dated 10-1-97 and Bill of Material 12-10-98
STD-M04	Standard 3" Meter Setting with 2" Meter for Vaults -Plan- Dated 10-1-97 and Bill of Material 11-19-98
STD-M05	Standard 3" Meter Setting with 2" Meter for Vaults -Elevation- Dated 10-1-97 and Bill of Material 11-19-98
STD-M06	Standard 3" Meter Setting with 3" Meter for Vaults -Plan- Dated 10-1-97 and Bill of Material 11-19-98

<u>Detail No.</u>	<u>Standard Detail</u>
STD-M07	Standard 3" Meter Setting with 3" Meter for Vaults-Elevation- Dated 10-1-97 and Bill of Material 11-19-98
STD-M08	Standard 4" Meter Setting with 4" Meter for Vaults Dated 10-1-97 and Bill of Material 11-19-98
STD-M09	Standard 4" Meter Setting with 3" Meter for Vaults Dated 5-18-98 and Bill of Material 11-19-98
STD-M10	Standard 6" Meter Setting with 6" Meter for Vaults Dated 4-26-2005 and Bill of Material 4-26-2005
STD-M11	Standard 6" Meter Setting with 4" Meter for Vaults Dated 5-18-98 and Bill of Material 11-19-98
STD-M12	Standard 8" Meter Setting with 8" Meter for Vaults Dated 10-1-97 and Bill of Material 11-19-98
STD-M13	Standard 8" Meter Setting with 6" Meter for Vaults Dated 4-26-2005 and Bill of Material 4-26-2005
STD-M14	Standard 12" Meter Setting with 12" Meter for Vaults Dated 10-1-97 and Bill of Material 3-6-2009
STD-M15	Typical 3", 4", 6", and 8" Meter Settings with 1", 1-1/2" Or 2" Lawn Sprinkler Connection Dated 1-4-2010
STD-M16	Typical 1-1/2" & 2" Meter Settings with 1" & 1-1/2" Lawn Sprinkler Connection Dated 10-1-97
STD-M17	Approved Inside Building Meter Settings for 1" Meters Dated 2-4-2013
STD-M18	Approved Inside Building Meter Settings for 1" Meters for Sewer Exemption. Dated 12-3-2012
STD-M20	Approved Inside Building Meter Setting for 1-1/2" Meter and Backflow Assembly. Dated 10-1-97
STD-M22	Approved Inside Building Meter Setting for 2" Meter and Backflow Assembly. Dated 10-1-97
STD-M24	Approved 1" Meter Setting for 1" Meter and Backflow Assembly for Vaults Lawn Irrigation only Dated 8-22-2012
STD-M25	Standard 1-1/2" Meter Setting with 1-1/2" Meter in Vault for 2" Connection Dated 1-12-1999 and Bill of Material Dated 1-12-99
STD-M26	Standard 1" Meter Setting with 1" Regulator for 2" Connection in Vault Dated 1-12-1999
STD-M27	Standard 1" Meter Setting with 1" Regulator for 1-1/2" Connection in Vault Dated 1-12-1999
STD-M28	Standard 1" Meter Setting for 2" Connection in Vault Dated 1-12-1999

<u>Detail No.</u>	<u>Standard Detail</u>
STD-M29	Standard 1" Meter Setting for 1-1/2" Connection in Vault Dated 1-12-1999
STD-M30	Standard 1" Service Connection with Cleveland Standard Meter Pit with Regulator Detail in Public Right Of Way Dated 10-12-2007
STD-M31	Standard 1" Service Connection with Cleveland Standard Meter Pit Detail in Public Right Of Way Dated 10-12-2007
STD-M33	3" Irrigation Meter Setting with 3" Meter Dated 8-22-2012 and Bill of Material Dated 8-22-2012
STD-M34	4" Irrigation Meter Setting with 4" Meter Dated 3-13-2000 and Bill of Material Dated 4-19-2000
STD-M35	6" Irrigation Meter Setting with 6" Meter Dated 4-19-2000 and Bill of Material Dated 4-19-2000
STD-M36	Large Meter Settings Inside Buildings Dated 9-15-2004
STD-M37	FM Approved 8" Compound Meter Assembly for Vault Dated 5-25-2001 with Bill of Material Dated 5-25-2001
STD-M38	Fm Approved 8" Compound Meter Assembly for Vault Sensus Meter Dated 6-25-2004 with Bill of Material Dated 11-29-2001
STD-M39	Fm Approved 12" Compound Meter Assembly for Vault Dated 6-25-2004 with Bill of Material Dated 6-25-2004
STD-M40	Approved 1-1/2" Meter Setting for 1-1/2" Meter and Backflow Assembly for Vaults Lawn Irrigation Only Dated 8-22-2012

Vault Arrangements

<u>Detail No.</u>	<u>Standard Detail</u>
STD-V01	Vault and Valve Arrangement Revised Dated 10-1-97
STD-V02	Typical Meter Settings, 3" Meter Settings and Larger for Inside Buildings. Dated 10-1-97
STD-V03	Single Feed/Combination Vault Domestic – Fireline Connections 3" Domestic - 4" - 10" Fireline – Dated 2-25-2009
STD-V04	Single Feed/Separate Vaults Domestic - Fireline Connections 4" - 12" Domestic - 4" -12" Fireline – Dated 2-25-2009
STD-V05	Single Feed/Single Vault for Fireline Connection/Domestic Connection with Remote Meter/1" - 2" Domestic/4" - 12" Fireline Dated 11-16-2009
STD-V06	Single Feed/Combination Vault Domestic - Fireline/Domestic Connection 1" - 2" Domestic/4" - 8" Fireline Dated 11-16-2009